

480 Rated Voltage, 600 Max Voltage, Low Z, Impedance.


Part Number	Horsepower (HP)	Motor Amps (A)	Maximum Amps (A)	Inductance (uH)	Weight (LBS)	Terminal Hole Diameter (Inches)	Losses (W)	Available Lug Kit
KDRH3L	100	124	150	152	35	0.28	225	SLK21
KDRH2L	125	156	165	117	35	0.28	254	SLK21
KDRH1L	150	180	185	103	35	0.28	299	SLK21

(Customer Connections) Markings On Coils For Reference Only.

TCI (800) 824-8282 transcoil.com
 TCI, LLC Germantown, WI, USA. transcoil.com 800-824-8282
 KDRH Drive Reactor
 KDR - Motor Amps -
 3PH, 50/60Hz, -V Rated, 600V Max, -A Max
 40C Amb Max, 150C Rise, Not IS
 Manual #30895 LUG KIT #SLK-
 UL LISTED CE
 2500V 1000V 1000V
 DATE CODE A1 A2 B1 B2 C1 C2

Notes:

1. KDR Lug Kits sold separately. Contact TCI.
2. UL file number: cULus Listed File E116124.
3. KDR Drive Reactors Comply With The Thermal and Altitude Standards Set Forth by NEMA ST20-1992.
4. KDR IOM Manual Part Number 30895
5. Material(s) Shall be RoHS Compliant
6. Customer Is Responsible For Installation To Meet All National And Local Electrical Codes.



THE INFORMATION AND DESIGNS CONTAINED IN THIS DRAWING ARE CONFIDENTIAL AND THE PROPRIETARY PROPERTY OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES. NEITHER THIS DESIGN NOR ANY INFORMATION CONTAINED IN THIS DRAWING MAY BE REPRODUCED OR DISCLOSED TO OTHERS WITHOUT THE EXPRESS WRITTEN CONSENT OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES.

NO	REVISION	DATE	BY	ANGULAR
C	6550, Add Lift Rings	1/30/2024	DSW	DECIMAL .XX ± .25 .XXX ± .10
B	6535, Bus to Flag Termination	1/10/2024	DSW	FRACTIONAL ± 1/32
A	6423, Copper bus to flag Terminals	9/27/2023	DSW	ANGULAR ± 1°

TCI W132N10611 (Rev 13) Rev 6
 Germantown, WI 53022 © 2024 TCI, LLC
 An Allied Motion Company
 KDR H Frame, (Flag Version)
 Reactor Drawing
 DESIGNED BY: DSW DATE: 9/27/2023 FILE: 107589-7DG
 SCALE: 1/2 DRAWN BY: DSW
 SHEET 1 OF 1